

35



Low Voltage: UT1001

3URGXFW 6SHFL;FDWLRQV

Heaters shall be equipped with a "manual reset" thermal overload which disconnects elements and motor in the event normal operating temperatures are exceeded. For safety, if opened due to abnormal temperature, thermal overload shall remain open until manually reset. Automatic reset thermal overloads which allow the elements to continue to cycle under abnormal conditions will not be accepted. Heaters shall be ETL listed.

- White powder coated 20 gauge grill.
- All units have manual reset thermal limit, 24V control
- WUDQVIRUPHU DQG 9 UHODI 12" x 12" x 12"
- ‡ (QFORVHG VWHHO ½ Q VKHDWK HO 745°F 12" x 12" x 12"
- Rough in dimensions: 23" sq. x 9 1/8" deep.
- Maximum mounting is 12'
- Made in U.S.A.

Standard Models

MFG CATALOG NUMBER	MFG MODEL NUMBER	KW	BTUs	VOLTS	PH	AMPS	TEMP RISE	
	03153302	2	6826	208	1	9.6	15 °F	
	03152602			H3482A1		240		8.3
	03149702			G3482A1		277		7.2
	03184702			P3482A1	480	4.2		
	04702802	2	6826	208	3	5.6	15 °F	
	03984902			K3482A1		240		4.8
	04702402			Y3482A1		480		2.4
	03153202			F3483A1	10200	208		1
	03148402	H3483A1	240	12.5				
	03148102	G3483A1	277	10.8				
	03184802	P3483A1	480	6.3				
	04706402	3	10200	208	3	8.3	22 °F	
	03985002			K3483A1		240		7.2
	04702502			Y3483A1		480		3.6
	03153602			F3484A1	13600	208		1
	03155402	H3484A1	240	16.8				
	03148002	G3484A1	277	14.4				
	03185002	P3484A1	480	8.3				
	03148702	4	13600	208	3	11.1	30 °F	
	03148202			K3484A1		240		9.7
	03185802			Y3484A1		480		4.8
	03154802			F3485A1	17000	208		1
	03155102	H3485A1	240	20.8				
	03185402	P3485A1	277	18.1				
	03185402	P3485A1	480	10.4				
	03180902	5	17000	208	3	13.9	37 °F	
	03180902			K3485A1		240		12.1
	03184002			Y3485A1		480		6.1
	03661002	PT3480	Recess Frame - Weight 5 lbs.					

International Models

1/8" Z-Cr 1500 W	0470971	M3482T2i	2	6826	220	1	9.1	15 °F
	0470988	N3482T2i			240		8.3	
	0470995	M3483T2i			220		13.6	
	0471008	N3483T2i			240		12.5	
1/8" Z-Cr 1500 W	0471015	M3484T2i	4	13600	220	1	18.2	30 °F
	0471022	N3484T2i			240		16.7	

Factory Installed Control Sections

SUFFIX	DESCRIPTION
ly S	Disconnect Switch
moreT	Thermostat
RELAYS FOR FIELD SUPPLIED CONTROL - NIGHTLY SETBACK	
R	5HOD\ &RQWURO 9ROWDJH 6DPH DV +HD
R1	5HOD\ 9 &RQWURO 9ROWDJH FRQW
R2	5HOD\ 9 &RQWURO 9ROWDJH FRQW

Product Dimensions

