



Representative Image

Catalog No. TL42422R

Description: MLO 225A 42CRT 3P4W 208Y/120V 3R

UPC No 783164062410

Home > Load Centers > Commercial/High-rise Residential

Panelboards No. 67 60 degree/75 degree centrifgrade Conductor Rating Suitable for use as service entrance equipment when Installed in accordance with the National Electrical Code 22kAIC RMS symmetrical, Except Where Noted 6-42 circuit devices UL Listed for bottom mounted lugs by installing complete unit (box, interior and front) upside down For a listing of CSA Listed load centers, visit www.geelectrical.com Amperage 225 A 422R2410

Descriptors

Category	Commercial/High-rise Residential
GO Schedule	R7

Specifications

Input/Output Voltage	208Y/120V ac
Type	Standard
Interrupting Capacity Rating	65
Amperage	225 A
Device type	Main Lugs
Enclosure	Outdoor Type 3R Enclosure
Phase	3 Phase
Socket Type	0
1" Space	42
1/2" Space	42
Feed	Either
Door	Yes
GSA Compliance	No

Classifications

UL/CUL Listing	UL
----------------	----

Publications

Title	Publication No.	Publication Type
PowerMark Gold* Load Centers, Q-Line Circuit Breakers and Accessories Guide Guide includes product features, photos, product number selection guide, knockout drawings, wiring diagrams, accessories and options list. Only available on-line. Outdoor Load Center 1 page outline drawing in pdf format.	DET1023 10103091-SH6	Application and Technical Drawings-Outline and Dimensional

Additional Documentation: Visit our Publication Library to find technical documentation, time current curves, CSI Specifications and promotional literature.